

Data Summary ATS-CR

Data Summary

Data File Name: ATS-CR- E1134-01

SAMPLE - SAMPLe - SAMPLe - SAMPLe - SAMPLe

First Data Record End Time: 07/09/08 09: 10: 00

Last Data Record End Time: 08/11/08 09: 25: 00

Monitoring Period Duration: 33.01 days

	Average	Maximum (Date Time)	Minimum (Date Time)	Total
Chan 1 Inst. Volt	279.2	283.3 (07/28/08 03: 05: 00)	274.4 (07/10/08 14: 05: 00)	2654333.9
Chan 1 Max. Amp	309.77	381.97 (08/11/08 07: 50: 00)	247.15 (08/06/08 04: 55: 00)	2945327.21
Chan 1 Avg. Amp	304.32	372.70 (07/22/08 09: 40: 00)	238.73 (08/06/08 04: 55: 00)	2893464.72
Chan 1 Avg. KW	81.077	99.874 (07/22/08 09: 40: 00)	62.093 (08/06/08 04: 55: 00)	770883.999
Chan 2 Inst. Volt	277.9	282.1 (08/10/08 03: 10: 00)	273.3 (07/24/08 11: 50: 00)	2642093.1
Chan 2 Max. Amp	279.79	393.65 (08/05/08 15: 30: 00)	233.24 (07/27/08 04: 15: 00)	2660220.62
Chan 2 Avg. Amp	274.45	337.66 (08/05/08 15: 15: 00)	226.37 (08/06/08 05: 25: 00)	2609474.78
Chan 2 Avg. KW	72.625	90.838 (07/16/08 09: 35: 00)	60.174 (07/24/08 02: 45: 00)	690515.411
Chan 3 Inst. Volt	278.9	283.6 (07/15/08 22: 50: 00)	273.6 (07/10/08 14: 05: 00)	2652245.9
Chan 3 Max. Amp	296.27	483.99 (07/28/08 13: 15: 00)	244.74 (07/14/08 02: 10: 00)	2816914.69
Chan 3 Avg. Amp	290.29	384.72 (08/05/08 15: 15: 00)	238.39 (08/06/08 05: 20: 00)	2760114.14
Chan 3 Avg. KW	74.834	98.957 (08/05/08 15: 15: 00)	60.942 (08/06/08 05: 20: 00)	711525.613
Chan 5 Avg. Amp	869.06	1063.82 (08/05/08 15: 15: 00)	708.85 (08/06/08 04: 55: 00)	8263046.85
Chan 5 Avg. KW	228.538	277.964 (07/16/08 09: 45: 00)	184.955 (08/06/08 04: 55: 00)	2172938.392

Setup Summary

Setup Table Description: NFRMC7-2008

Channel 1 - Power: VHi: L1, VLo: N; PT = 1.000; CT = 3000.000
 Channel 2 - Power: VHi: L2, VLo: N; PT = 1.000; CT = 3000.000
 Channel 3 - Power: VHi: L3, VLo: N; PT = 1.000; CT = 3000.000
 Channel 5 - Power Sum: 1, 2, 3

Memory Type: Ring
 Line Frequency: 60 Hz
 Integration Period: 5 Minutes

Logger Summary

Logger Description Line: FMRC ATS-CR
 Logger Serial Number: E1134
 Logger type: ELITEpro
 Firmware Version: IL400.036

SAMPLE - SAMPLe - SAMPLe - SAMPLe - SAMPLe

Data Summary ATS-CR