




MJM Electric, Inc.
 3225 East 4th Avenue, Tampa, FL 33605
 PH (813) 248-1711 - FX (813) 247-5011
Safety and Quality are our Priorities

Power Quality Readings

Customer:	Sample Customer	Date:	9/1/2008
-----------	-----------------	-------	----------

Facility:	Sample Facility	Panel FIDA
-----------	-----------------	------------

Normal Power Current Readings



DATA		COMMENTS
FREQUENCY	60	Readings show that phases are balanced and within service limits.
A PHASE RMS	58.37	
B PHASE RMS	61.07	
C PHASE RMS	80.42	
NEUTRAL RMS	36.31	