

Visual Discrepancies

Customer:	Sample Facility	Date 9/1/2008	Survey 4
-----------	------------------------	-------------------------	--------------------

Discrepancy		
Item Inspected	Location	Equipment ID
GFCI Receptacle 110Volt GFCI Duplex Recept.	Power & Control Panel	20Amp Recept.
Problem Description		Problem Solution
GFCI receptacle will not reset.		De-energize and replace receptacle.

Digital Camera Image

